



Trimo UK Ltd.

Unit 4, Willaston House Business Centre
Crewe Road, Willaston, Nantwich, CW5 6NE
T: +44 1270 665303, F: +44 1270 664294
E: trimo@trimo.org.uk, I: www.trimo.org.uk

21st September 2016

Dear Neil

Ref: Richardo, Shoreham

As agreed repair was undertaken carried out by CJ Coatings to the FTV and QbissOne wall panels following the site visit of the 2nd June 2016 to identify the damaged panels.

C J Coating is a company used successfully by Trimo for many years and their work is carried out fully to Trimo specifications.

We would comment that due to the very nature of on-site spraying it is not possible to replicate perfectly the texture and consistency of factory coated Tata Colorcoat Prisma coil and it is always going to be possible when viewing newly painted panels at certain angles and in certain light conditions to note shade variation and surface gloss levels. This will also be affected when viewing panels which have been recently coated against panels which have been subject to UV exposure and natural weathering.

It is also possible to note slight imperfections at the site of the repair if viewed at close proximity depending upon the profile of the steel substrate and level of damage sustained. Industry standards and Trimo's specification state that repairs should be viewed while standing directly in front of the panel at a distance of 3 metres.

We hope this confirms the position but if you or your client wish to discuss this matter in further detail then please do not hesitate to contact us.

Regards

Mark Lewis

Key Account Director

 / Unit 4, Willaston House Business Centre, Crewe Road / Williston, Nantwich CW5 6NE /

T: 1270665303 / F: 01270664294 /

Mob: 0773 854 4828

E: mark@trimo.org.uk / I: www.trimo.org.uk